

An aerial photograph of a large dam structure, likely a concrete gravity dam, with multiple spillways. The dam is situated in a valley, and the water level is visible behind the dam. The foreground shows the concrete structure of the dam, and the background shows the river valley and surrounding landscape.

# Dams as Systems

Pat Regan

Federal Energy Regulatory Commission  
(FERC)

# FERC

- >2,500 jurisdictional dams
  - 770 feet to 0.5 feet high
- Five Regions
  - Atlanta, Chicago, New York, Portland, San Francisco
- ~120 staff














A contemporary illustration of the broken South Fork Dam from Harper's Weekly.



# Potential Energy

- A major dam like Grand Coulee or Oroville can store more than 100 times the energy released by the atomic bomb dropped on Hiroshima.
- The Sayano-Shushenskaya dam in Russia stores nearly 800 times the energy of the Hiroshima bomb.



A black and white photograph showing a large, rectangular sign with the words "WANTED", "DAMN ENGINEER", and "DEAD OR ALIVE" written in large, hand-painted letters. The sign is leaning against a wooden fence. In the background, there is a small, white, single-story building with a porch and a window. To the left, a dark-colored pickup truck is parked on a gravel or dirt area. The overall scene appears to be a residential or industrial site.

WANTED  
DAMN ENGINEER  
DEAD OR ALIVE

# Pre-Teton Dam (1976)

- **Strictly standards based**
- **Three loading conditions**
  - Static (normal)
  - Flood (unusual)
  - Seismic (extreme)
- **Defined minimum factor of safety**
  - Static (3.0\*)
  - Flood (2.0\*)
  - Seismic (1.3\*)

# Federal Guidelines for Dam Safety

- **Three categories of dams**
  - High Hazard Potential
    - Dams where failure or mis-operation will probably cause loss of human life. (one or more)
  - Significant Hazard Potential
    - Dams where failure or mis-operation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns.
  - Low Hazard Potential
    - Dams where failure or mis-operation results in no probable loss of human life and low economic and/or environmental losses.

# Post Teton

- Reclamation implemented a risk-based dam safety program
  - For the most part still only worried about the three loading conditions but included “piping”, the cause of the Teton failure
- Post Katrina, USACE is developing a risk-based program.
- Most states and the FERC are still in a deterministic world
  - FERC is in the process of developing a risk-informed approach









DEC 15 2005



# Taum Sauk Report

- It is our conclusion that the **root cause** of “*the uncontrolled, rapid release of water from the Upper Reservoir*” was the breach of the Rockfill Dike—a stability failure at the northwest corner of the Reservoir brought on by a rapid increase in the pore pressure at the Dike/foundation interface, stemming from the original design and construction which was flawed.

	Phase						
	Design	Initial Construction	Operation State 1 (1963-1990)	Operation State 2 (1990s)	“Remediation” (2004)	Operation State 3	Failure
Design	<p>Location limited surface area of reservoir. Needed storage volume required 10’ high parapet wall with 8’ of water stored against wall</p> <p>Assumed clean rockfill</p> <p>No spillway included</p> <p>Emergency shut-off system includes high water alarm (alarm in PH) and high-high alarm (shuts off pumps at 1’ remaining freeboard)</p> <p>Water level monitoring equipment placed near “morning glory” inlet-outlet works (shortest distance to PH)</p>	<p>Dirty Rockfill at best, rocky earthfill in some areas</p> <p>Instrumentation firmly fastened to concrete upstream face</p>	<p>Excessive settlement (~1’ in 4.5 years)</p> <p>Water flow causes vortex development at inlet-outlet</p>	<p>Continuing settlement, up to ~2’, results in cracking of concrete face slab and mis-alignment of parapet wall resulting in excessive seepage through dam</p>	<p>Geomembrane liner installed on upstream face to reduce seepage</p> <p>Penetration of liner not allowed. Instruments supported from top of dam to bottom by “suspension” system. Turnbuckle nuts not locked</p> <p>PVC conduit houses instruments</p> <p>Emergency shut-off system installed at “design” elevations (ignoring the 2’ of settlement that had taken place)</p>	<p>Vibration from vortices loosens nuts on instrument support system</p> <p>PVC conduit bends due to vortices thereby giving erroneous water levels</p>	<p>On December 14, 2005, at about 0510 the dam overtopped during a pumping operation. The water level alarms did not sound because both alarms had to trigger to sound an alarm (after being rewired in parallel) and the high-high water alarm was about two feet higher than the lowest point on the wall (due to ignoring the settlement). Due to the lack of a spillway the parapet wall overtops. The water falls 10’ onto the earthen embankment rapidly eroding the material and undermining the parapet wall. The wall overturns unleashing a 10’ wall of water that rapidly erodes the remaining embankment. It took only about 12 minutes to drain the reservoir. Peak outflow was estimated at 289,000 cfs (more than the Mississippi River above its confluence with the Ohio River). Luckily a downstream park and campground was empty due the time of year and 5 people in a house survived even though the house was swept from its foundation.</p>
Operation	<p>1-2 pump cycles per week</p> <p>One unit used to pump</p>		<p>Experienced local operating staff</p> <p>Operations staff adjust water level controls to account for settlement</p>	<p>Profit driven operation</p> <p>Remote operation</p> <p>Pump-turbines replaced, 25% greater capacity (1999)</p> <p>Multiple pump cycles/day</p> <p>Two unit pumping</p>		<p>High water and high-high water level instruments re-wired in parallel to eliminate “false” readings</p> <p>Operators reprogram computer to “account” for deflection of conduits</p> <p>Overtopping events on Sept. 25 and 27, 2005</p>	
Organization	<p>No person designated to assure dam safety</p>		<p>Adjustment of water level controls not documents</p> <p>Arrogance - (letter to a FPC engineer) “<b>I told him there would be no structural damage if the pumps failed to shut down</b>”. (1968)</p>	<p>Retirement of experienced staff</p> <p>Loss of institutional knowledge</p> <p>No one considers impact of changed operation</p>		<p>Repair to water level conduits delayed until future planned outage to minimize impact on generation</p>	
Societal Decisions	<p>Rate of Return cost structure</p>			<p>Deregulation of electric industry (~1997). No guaranteed rate of return</p>			






Figure 2 – Interaction Flow Chart – Taum Sauk Upper Dam Failure



# The March to Failure




# The March to Failure







# The March to Failure




# The March to Failure



# The March to Failure





**Sediment Splay and Depositional Zone**

**Foundation of Park Superintendent's Home**

**Car-Sized Boulder (Next Slide)**

**Downed Tree Orientation Shown in red – Current direction indicators**

**Scour And Deposition Zone**

**Highway N**

# My Interests

- How can we use use systems engineering approaches to improve dam safety practices?
- How can we use systems engineering approaches to structure our approach to regulation?

# My Interests

- Using Techniques and Practices built on STAMP to:
  - Guide Hazard Analysis
  - Guide Accident/Incident Causal Analysis and Understanding
  - Guide development of guidelines
  - Guide a study of the organizational structure of the FERC dam safety program