

# MAINTAINING SAFETY IN FUTURE GAS SYSTEMS

The Need to Include Systemic Risk Assessments


*How can we assess risks in complex gas systems?*

# Outline

- Gas Systems
- Risk Assessments
- Conclusion

# Gas Systems (1/2)


## Conventional Gas System




# Gas Systems (2/2)

- Increasingly characterized by
  - Non-linear interactions
  - Feedback loops
  - Interconnected subsystems


# Gas Booster



# Gas Booster



# Gas Booster





# Risk Assessments

- Hazard and Operability Study (HAZOP)
  - Executed by grid operator
  - Focus on gas booster
- System-Theoretic Process Analysis (STPA)
  - Executed with grid operator
  - Focus on effects of gas booster

# Pressure: Hazards and Accidents

---

## HAZOP

*Incoming pressure too high*

- Unfiltered gas in system
- Gas escapes system

## STPA

*Gas pressure in source grid leaves acceptable boundary levels*

- Fire/Explosion
- Poisoning
- Loss of operator revenue
- Loss of producer revenue

# Pressure: Hazards and Causes

---

## HAZOP

*Incoming pressure too high*

## STPA

*Gas pressure in source grid leaves acceptable boundary levels*

# Pressure: Hazards and Causes

## HAZOP

*Incoming pressure too high*

- 4 bar grid pressure too high
- Pressure regulator defective
- Pressure regulator out-of-spec

## STPA

*Gas pressure in source grid leaves acceptable boundary levels*

### UCA-1-SCENARIOS

- *Software is installed so that abort/decrease cmd. overrides initiate cmd. (possible conflicting parameters: destination grid pressure > 8.2 bar; gas is off-spec)*
- *Process model regarding source grid pressure is wrong*
- *Process model regarding destination grid pressure is wrong*
- *Process model regarding gas quality is wrong*
- *Control algorithm sends inappropriate CA based on inconsistent process model or faulty design*
- *Hostile takeover (computer hack) leads to inappropriate CA*
- *Initiate cmd. not (or too late) received by remote control*
- *Remote control delays sending initiate cmd.*
- *Compressor fails to follow up on initiate cmd.*
- *Off-spec gas is detected at compressor (i.e. continuous gas quality sensor is defective; power outage but gas keeps flowing; shut-off valve is defective)*
- *Gas that is sent to the grid becomes off-spec before it reaches the compressor*
- *Compressor failure*
- *Power outage (but biogas production continues)*
- *Changing supply and demand increase gas pressure in segments of the grid not registered by the sensor*
- *Sensor fails to measure grid capacity correctly*
- *Sensor fails due to power outage*
- *Sensor sends faulty or no information regarding grid pressure*
- *Mechanical stop is shut in the compressor*
- *Multiple boosters (or large biogas producers) are connected to one destination grid and have priority*

# Pressure: Hazards and Causes

---

## HAZOP

*Incoming pressure too high*

- 4 bar grid pressure too high
- Pressure regulator defective
- Pressure regulator out-of-spec

## STPA

*Gas pressure in source grid leaves acceptable boundary levels*

- Hostile takeover (computer hack) leads to inappropriate CA

# Quality: Hazards and Accidents

---

## HAZOP

*Outgoing gas too warm*

- Gas escapes system
- Gas degrades infrastructure and attached appliances

## STPA

*Feeding in of out-of-spec gas into the destination grid*

- Fire/Explosion
- Poisoning
- Loss of operator revenue

# Quality: Hazards and Causes

---

## HAZOP

*Outgoing gas too warm*

## STPA

*Feeding in of out-of-spec gas into the destination grid*

# Quality: Hazards and Causes

---

## HAZOP

---

*Outgoing gas too warm*

- Cooling not functioning
- Heat exchange not functioning

## STPA

---

*Feeding in of out-of-spec gas into the destination grid*

### UCA-33 SCENARIOS

- Software is installed so that initiate cmd. overrides abort/decrease cmd. (possible conflicting parameters: source grid pressure >3.8 bar;
- Process model regarding gas quality is wrong (critical parameters are not tested)
- Control algorithm sends inappropriate CA based on inconsistent process model or faulty design
- Hostile takeover (computer hack) leads to inappropriate CA
- Abort or Decrease cmd. not (or too late) received by remote control
- Remote control delays sending Abort or Decrease cmd.
- Compressor fails to follow up on Abort or Decrease cmd.
- Off-spec gas is sent to the grid (i.e. continuous gas quality sensor is defective; power outage but gas keeps flowing; half-yearly parameters not frequent enough due to changing gas biomass source; shut-off valve is defective)
- Gas that is sent to the grid becomes off-spec before it reaches the compressor
- Compressor failure
- Sensor for quality control fails due to power outage (but biogas production continues)



# Quality: Hazards and Causes

---

## HAZOP

*Outgoing gas too warm*

- Cooling not functioning
- Heat exchange not functioning

## STPA

*Feeding in of out-of-spec gas into the destination grid*

- Process model regarding gas quality is wrong (critical parameters are not tested)

# Conclusion

- Systemic hazards not adequately covered by HAZOP
  - Separately identified by HAZOP team
- STPA complementary
  - “Not-yet-hazards”
  - Use of software

# Questions?

b.riemersma@tudelft.nl

